

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

April 16, 2009

WATER QUALITY ASSOCIATION PAULI UNDESSER 4151 NAPERVILLE ROAD LISLE IL 60532 PROTECT PLUS LLC GLENN CUEMAN 11515 VANSTORY DRIVE, STE 135 HUNTERSVILLE NC 28078

Re: Description: WATER TREATMENT DEVICE-ACTIVATED CARBON

Manufacturer: PROTECT PLUS LLC

Product Name: DUPONT 2 STAGE DRINKING WATER SYSTEM (POU)

Model Number(s): WFQT270005 USING THE WFQTC70001 AND WFQTC3001 CARTRIDGES

(POU)

Product File No: 20080594

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2014.

This approval is contingent upon compliance with the following stipulation(s):

- > This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If this approved device is modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- These devices will only reduce the concentration of volatile organic chemicals at water outlets that are served by the devices. There are dermal (skin) absorption and inhalation exposure risks associated with volatile organic chemicals. Therefore, using point-of-use devices such as these will not protect all routes of potential exposure. Potentially hazardous exposures to volatile organic chemicals will remain possible at unprotected outlets, particularly hot water outlets (e.g. bathing, showering, clothes washing or dish washing).
  - If, by way of reputable water analyses, a water supply is known to contain unsafe levels of volatile organic chemicals, then all the water entering the residence must be treated at the point-of-entry using an approved water treatment device to address all potential routes of exposure.
- If the treatment components of this device (e.g. replacement cartridge) are replaced with anything other than those originally approved for use with this device, then this approval shall immediately be considered null and void.

SBD-10564-E (N.10/97) File Ref: 08059401.DOC

Protect Plus LLC April 16, 2009 Page 2 of 4

Product File No.: 20080594

These devices will only reduce the concentration of cysts/oocysts at water outlets that are served by the devices. Therefore, using point-of-use devices such as these will not protect all routes of potential exposure. Potentially hazardous exposures to cysts/oocysts will remain possible at unprotected outlets.

The presence of cysts/oocysts strongly suggests that other pathogens (e.g. bacteria, virus) may also be present.

If, by way of reputable water analyses, a water supply is known to contain cysts/oocysts, then all the water entering the residence must be treated at the point-of-entry, using an approved water treatment device, to address all potential routes of exposure thereby providing a biologically safe water supply.

Based on testing data submitted to and reviewed by the department, this approval recognizes that this plumbing product will reduce the concentration of contaminants as specified on pages 1 through 4 of this letter.

## AESTHETIC CONTAMINANT REDUCTION CAPABILITIES PRODUCT FILE NUMBER 20080594 TABLE 1 OF 4

Flow Rate:

1.9 liters per minute (lpm) [0.5 gallon per minute (gpm)]

Capacity:

1,514 liters (I) [400 gallons (gals.)], for particulate reduction, for all models, the capacity is dependent on the type and quantity of particulate matter present in the untreated water; the need for maintenance may be indicated be a significant decrease in flow rate.

Tested Contaminant	Influent Challenge (mg/l)*, 1
Chlorine (free)	2.0 ± 10%
Particulates (0.5 to < 1.0 μm)	≥ 1.0 x 10 <sup>4</sup> #/ml

**Other Conditions**: the contaminant reduction performance capabilities displayed for Table 1 of 4 were verified by testing conducted in accordance with NSF *International* Standard 42. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations by  $\geq$  50%; meeting the free chlorine reduction requirements also qualifies the device for the reduction of aesthetic, organic, taste and odor reduction (e.g. geosmin, methylisoborneol); this does not include hydrogen sulfide. To qualify for particulate reduction (Class I) the device must reduce the influent challenge concentrations by  $\geq$  85%.

1 = milligrams per liter (mg/l) are equivalent to parts per million (ppm)

≥ = greater than or equal to

 $\pm$  = plus or minus

#/ml = particles per milliliter

< = less than

 $\mu m = micrometers$ 

\* = unless otherwise specified

≤ = less than or equal to

Protect Plus LLC April 16, 2009 Page 3 of 4

Product File No.: 20080594

## HEALTH EFFECTING INORGANIC CONTAMINANT REDUCTION CAPABILITIES PRODUCT FILE NUMBER 20080594 TABLE 2 OF 4

Flow Rate: 1.9 liters per minute (lpm) [0.5 gallon per minute (gpm)]

Capacity: 1,893 liters (I) [500 gallons (gals.)], for asbestos reduction, the capacity is dependent on

the type and quantity of particulate matter present in the untreated water; the need for

maintenance may be indicated be a significant decrease in flow rate.

Tested Contaminant	Influent Challenge Concentration (mg/l) <sup>1</sup>
Lead (Pb <sup>+2</sup> ) <sup>2</sup>	0.15 ± 10%

**Other Conditions:** the contaminant reduction performance capabilities displayed for Table 2 of 4 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for lead reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are  $\leq 0.010$  mg/l.

1 = milligrams per liter (mg/L) are equivalent to parts per million (ppm)

2 = metals are tested at pH 6.5 and pH 8.5

≤ = less than or equal to

**±** = plus or minus

## HEALTH EFFECTING BIOLOGICAL CONTAMINANT REDUCTION CAPABILITIES PRODUCT FILE NUMBER 20080594 TABLE 3 OF 4

Flow Rate: 1.9 liters per minute (lpm) [0.5 gallon per minute (gpm)]

**Capacity:** dependent on the type and quantity of particulate matter present in the untreated water;

the need for maintenance may be indicated be a significant decrease in flow rate.

Tested Contaminant	Influent Challenge (#/ml)
Cysts/Oocysts <sup>1</sup>	$\geq 5.0 \times 10^4$

**Other Conditions**: the contaminant reduction performance capabilities displayed for Table 3 of 4 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for cyst/oocyst reduction, the device must reduce the influent challenge concentrations by  $\geq$  99.95% at each sample point.

1 = the specific organisms covered under this testing protocol include cryptosporidium parvum, entamoeba histolytica, giardia lamblia and toxoplasma gondii
 mI = particles per milliliter

≥ = greater than or equal to

Protect Plus LLC April 16, 2009 Page 4 of 4

Product File No.: 20080594

## HEALTH EFFECTING ORGANIC CONTAMINANT REDUCTION CAPABILITIES PRODUCT FILE NUMBER 20080594 TABLE 4 OF 4

Flow Rate: 1.9 liters per minute (lpm) [0.5 gallon per minute (gpm)]

Capacity: 1,893 liters (I) [500 gallons (gals.)]

Tested Contaminant	Influent Challenge Concentration (µg/l) <sup>1</sup>
Atrazine	9.0 ± 10%
Lindane	2.0 ± 10%

Other Conditions: the contaminant reduction performance capabilities displayed for Table 4 of 4 were verified by testing conducted in accordance with NSF *International* Standard 53. To qualify for atrazine reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are  $\leq 3.0 \, \mu g/l$ . To qualify for lindane reduction, the device must reduce the influent challenge concentrations such that all effluent concentrations are  $\leq 0.2 \, \mu g/l$ .

 $1 = \text{micrograms per liter } (\mu g/I) \text{ are equivalent to parts per billion } (ppm)$ 

≤ = less than or equal to

 $\pm$  = plus or minus

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**(608) 267-9566 **Fax**glen.schlueter@wi.gov **Email**8:00AM – 4:30PM CDT **Work Hours** 

GWS:gws